

# ADEQ

ARKANSAS  
Department of Environmental Quality

April 19, 2012

Larry Dunaway  
Public Works Director  
City of Nashville  
426 N. Main Street  
Nashville, AR 71852

RE: NPDES Permit No. AR0021776, AFIN 31-00036

Dear Mr. Dunaway:

A review of the NPDES file for the City of Nashville for the monitoring period of July 1, 2011 thru January 31, 2012 revealed the following compliance issue:

The facility reported 1 violation of Part I, Section A. of NPDES Permit No.: AR0021776. The effluent violation reported on the DMR is as follows:

DMR End Date	Discharge	Parameter	Reported Value	Permit Limit
07/31/11	001A	Solids, total suspended (MO AVG, mg/L)	16.25	15

The Department expects the City of Nashville to continue to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0635, or you may e-mail me at [anderson@adeq.state.ar.us](mailto:anderson@adeq.state.ar.us).

Sincerely,



Alan Anderson  
Enforcement Analyst  
Water Division / Enforcement Branch