



City of Nashville

Mayor Larry Dunaway
426 N Main St
Nashville, AR 71852



February 14, 2023

ADEQ
Attn: Water Quality Enforcement
Division of Environmental Quality
5301 Northshore Drive
North Little Rock, AR 72118-5317


Re: Unpermitted Discharge Nashville WWTP
Permit #0021776 AFIN: 310036

To whom it may concern,

The unpermitted discharge reported on February 9, 2023 stopped on Monday February 13, 2023 at 7:00 am. The overflow was due to an excessive rainfall event of 4.52 inches. The overflow is estimated to be 28 gpm or 4 million gallons over a period of 96 hours.

If you have any questions or concerns, please call my office at 870-845-7400.

Sincerely,


Larry Dunaway
Mayor
City of Nashville

870-845-7400



npw@nashar.org



Nashar.org



870-845-7409



City of Nashville

Mayor's Office

426 N Main St

Nashville, AR 71852

SHREVEPORT LA 710

14 FEB 2023 PM 3 L

ADEQ

Attn: Water Quality Enforcement

Division of Environmental Quality

5301 Northshore Drive

North Little Rock, AR 72118-5317

72118-531799

