

Lawrence, Myrl

From: Lawrence, Myrl
Sent: Monday, June 7, 2021 3:06 PM
To: 'bvcityhall@berryville.com'
Cc: 'jeff.hickle@jacobs.com'
Subject: DMR Violations AR0021792 Berryville



ARKANSAS
ENERGY & ENVIRONMENT

June 7, 2021

Honorable Tim McKinney
Mayor, City of Berryville
P.O. Box 227
Berryville, AR 72616

Email: bvcityhall@berryville.com

RE: Permit Number AR0021792 Berryville
Effluent Violations

Dear Mayor McKinney:


A review of the Discharge Monitoring Reports (DMR) submitted to DEQ during the period January 1, 2020, through April 30, 2021 indicated the following violations:

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value
12/31/2020	TX1-Q	Whole effluent toxicity (7 DA MIN, %)	75	100
02/28/2021	001-A	Coliform, fecal general (7 DA GEO, #/100mL)	2585	2000
03/31/2021	TX1-Q	Whole effluent toxicity (DLYAVMIN, %)	<32	100
03/31/2021	TX1-Q	Whole effluent toxicity (7 DA MIN, %)	<32	100

Non-compliance reports addressing the violations were received and deemed adequate.

As a reminder, any violation is subject to enforcement by DEQ in accordance with environmental law. While any violation of the Permit is subject to further enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act, at this time, no additional actions are being proposed. Should additional violations occur, this violation will be taken into consideration when determining any future enforcement actions. The regulations and your Permit require that you continue to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Should you have any questions or desire assistance, please contact me directly.

Kindest Regards,



Myrl V Lawrence Jr | Enforcement Analyst
Division of Environmental Quality | Office of Water Quality
Enforcement Branch
5301 Northshore Drive, North Little Rock, AR 72118
t: 501.682.0699 | c: 501.319.5055 | e: myrl.lawrence@adeq.state.ar.us

ARKANSAS DEPARTMENT OF ENERGY AND ENVIRONMENT