

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
Office of Water Quality – Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Permit No: AR0021792 Discharge Number: 001  
Facility: City of Berryville  
Address: 1000 Cedarvale Rd.  
City: Berryville State: AR Zip: 72616  
Contact: Thom Vinson Phone: 479-443-3292

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
2/16/2021	Fecal Coliform 7-day maximum		2585	2000

We feel this problem was due to:

~~During the week of February 14, 2021, we had severe cold weather causing our aeration basin temperature to drop as low as 4.25 degree C. The following week the basin temperature increased to 9+ degree C and the fecal coliform count was back to normal.~~


We plan on correcting the problem in this manner:

~~Warmer ambient temperature returned the process to normal operation.~~

Time estimated that it will take to correct problem:

~~One week~~

Sincerely,

 Jay Lee  
City Admin. Assistant

Submitted By:

Date 3/18/2021

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)