

Lawrence, Myrl

To: bvcityhall@berryville.com
Cc: Jeff.Hickle@jacobs.com
Subject: Effluent Violations Warning 20170801 thru 20180731



August 1, 2018

Honorable Tim McKinney, Mayor
City of Berryville
P.O. Box 227
Berryville, AR 72616

RE: Berryville WWTF, NPDES Permit Number: AR0021792, AFIN08-00034
Effluent Limit Violations

Dear Mayor McKinney:

A review of the NPDES file for the above referenced facility for the period of August 1, 2017 through July 31, 2018 reveals the following compliance issues:

The facility has reported Five (5) effluent violations of Part I, Section A. of the Permit:

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio
06/30/2018	001-A	Coliform, fecal general, 30DA GEO, #/100mL	1000	>751	99,999%
06/30/2018	001-A	Coliform, fecal general, 7 DA GEO, #/100mL	2000	2647	32%
01/31/2018	001-A	Nitrogen, ammonia total [as N], MO AVG, lb/d	80.1	113.9	42%
01/31/2018	001-A	Nitrogen, ammonia total [as N], MO AVG, mg/L	4	8.1	103%
01/31/2018	001-A	Nitrogen, ammonia total [as N], 7 DA AVG, mg/L	6	15	150%

Non-compliance Reports were received by the Department, and the corrective actions taken were accepted as reasonable and prudent measures. As a reminder, any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you continue to take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Your attention to this matter is most appreciated. Should you have questions or desire assistance please contact me directly.

Sincerely,

Handwritten signature of Myrl V. Lawrence Jr. in black ink.

Myrl V Lawrence Jr
Enforcement Analyst
ADEQ Office of Water Quality
Phone: 501-682-0699
Fax: 501-682-0880
myrl.lawrence@adeq.state.ar.us

cc: Jeff Hickle, Environmental Projects Specialist, Jacobs Engineering, Jeff.Hickle@jacobs.com

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY
5301 NORTHSHORE DRIVE / NORTH LITTLE ROCK / ARKANSAS 72118-5317
TELEPHONE 501-682-0744 / FAX 501-682-0880 / www.adeq.state.ar.us