Mayo,

I received this from Alan as I am the enforcement analyst for the City of Berryville. Was the discharge from their permitted outfall? I will need more information and a follow-up report signed and dated by the facility's signatory official. Feel free to contact me if you have any questions.

Thanks,

Jacqueline Trotta Enforcement Analyst Water Division Arkansas Department of Environmental Quality 5301 Northshore Drive North Little Rock, AR 72118 501-682-0632

From: Anderson, Alan
Sent: Wednesday, July 22, 2015 10:18 AM
To: Trotta, Jacqueline
Subject: FW: AFIN #08-00034 Permit #AR0021792, Berryville WWTP, Partially Treated Effluent Discharge

FYI

From: <u>Mayo.Miller@ch2m.com</u> [<u>mailto:Mayo.Miller@ch2m.com</u>]
Sent: Tuesday, July 21, 2015 8:15 PM
To: Anderson, Alan
Cc: <u>Billy.Ammons@CH2M.com</u>; <u>kirbymurray@gmail.com</u>; <u>Mayo.Miller@ch2m.com</u>
Subject: AFIN #08-00034 Permit #AR0021792, Berryville WWTP, Partially Treated Effluent Discharge

Alan,

We wish to inform you of a partially treated effluent discharge at the Berryville WWTP. At approximately 2:00 a.m. on 21 July, 2015, a mechanical failure in the UV disinfection system allowed an estimated 517,000 gallons of partially treated effluent to discharge from the treatment facility. Necessary repairs were completed and the UV system was placed back into operation at approximately 9:00 a.m. Besides UV disinfection, the discharge received treatment from all treatment processes at the facility.

No environmental impact has been observed and none is expected.

Please let me know if you have any questions.

Best Regards,

Mayo Miller

Assistant Project Manager D 479 443 3292 F 479 443 5613 M 435 690 1955

CH2M

1400 N Fox Hunter Road Fayetteville, AR 72701 www.ch2m.com | LinkedIn | Twitter | Facebook