

# ADEQ

A R K A N S A S  
Department of Environmental Quality

July 5, 2017

Honorable Tim McKinney  
Mayor, City of Berryville  
P.O. Box 227  
Berryville, AR 72616

RE: NPDES Permit Number: AR0021792, AFIN08-00034  
Partially Treated Effluent Discharge Reports

Dear Mayor McKinney:


A review of the NPDES file for the above mentioned facility reveals the following compliance issues:

Since July 2015, the City of Berryville has reported 5 incident reports of partially treated effluent due to different events that led to failures of the UV system being discharged totaling over 1,320,000 gallons. The reports stated that corrective actions were performed to correct each issue. However, due to repeated occurrences of partially treated effluent being discharged due to UV system shutdowns, the Department recommends consulting with a professional engineer (PE) registered in the state of Arkansas for the purposes of evaluating the facility's operational procedures to determine if a Corrective Action Plan (CAP) is needed to address the discharges of partially treated effluent due to UV system failures. Please submit the evaluation report, certified by a PE, to the Department by **August 20, 2017**. If a CAP is needed, please include it with an expected date of compliance with the evaluation report.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0632, or you may e-mail me at [trotta@adeq.state.ar.us](mailto:trotta@adeq.state.ar.us).

Sincerely,



Jacqueline Trotta  
Enforcement Analyst  
Office of Water Quality, Enforcement Branch

cc: Tim Luther, Operations Manager, CH2M  
Mayo Miller, Project Manager, CH2M