

# City of Berryville Compliance Report

AR0021792


Month September

Year 2023

Type of Violation	Permit Limit	Permit Violation	Dates of Violation	Cause of Violation
Fecal- 30 Day Geometric	1000	1270	09/2023	UV

The City of Berryville is in the process of upgrading its UV system. With part delays and the ongoing project, the exceedances occurred. We anticipate full compliance this month.

I certify under penalty of law that I have personally examined the information submitted herein: and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. 18 U.S.C. 1001 and 33 U.S.C 1319 (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and five years.)

Signature of Cognizant or Ranking Official  Date 10/20/23