

City of Berryville

Public Works Department

P.O. Box 227
305 East Madison
Berryville, Arkansas 72616

Office of the Director, Kirby Murray

Phone: 870-423-4074
Fax: 870-423-4501
E-mail: kirbymurray@gmail.com

July 22, 2015

Ms. Jacqueline Trotta
Enforcement Analyst
Water Division
Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, AR. 72118
(501) 682-0632


Dear Ms. Trotta:

This letter serves as the requested follow-up report regarding the partially treated effluent discharge at the Berryville WWTP, AFIN #08-00034 Permit # AR0021792.

At approximately 2:00 a.m. On July 21, 2015, a mechanical failure in the UV disinfection system allowed an estimated 517,000 gallons of partially treated effluent to discharge from the treatment facility. Investigative efforts revealed that the A/C unit in the UV control cabinet failed causing a direct electrical short resulting in a shutdown of the UV system. This shutdown allowed water to pass through the UV channel to the permitted Outfall 001 without receiving the disinfection portion of the treatment process. The discharged water during the shutdown period received treatment from all treatment processes at the facility, except UV disinfection. Necessary repairs were completed and UV disinfection resumed at approximately 9:00 a.m. No environmental impact has been observed and none is expected.

Please contact me if you have any questions or need additional information.

Sincerely,



Kirby Murray

c: Mayo Miller, CH2M

City of Berryville


P.O. BOX 227 - 305 E. MADISON

Berryville, Arkansas 72616

NORTHWEST AR P&DF

AR 727 1 T

23 JUL 2015 PM



MS. JACQUELINE TROTTA
ENFORCEMENT ANALYST, WATER DIVISION
ADEQ
5301 NORTHSHORE DR
NORTH LITTLE ROCK, AR
72118

72118+5317

