

# ADEQ

A R K A N S A S  
Department of Environmental Quality

March 7, 2011

Berryville, City of - WWTP  
Attention: Kirby Murray  
P.O. Box 227  
Berryville, AR 72616

RE: NPDES Permit Number AR0021792, AFIN 08-00034

Dear Mr. Murray:

A recent review of the NPDES file for the City of Berryville WWTP has revealed the following violations for the monitoring period ending **12/31/2010**.

DISCHARGE NUMBER	PARAMETER	VIOLATION	LIMIT	UNITS
001-A	Nitrogen, ammonia total	7.3	6	mg/L

As you know, Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit require you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Please refer to NPDES Permit Number AR0021792 and AFIN 08-00034 in any written correspondence to ADEQ. Should you have any questions, feel free to contact me at 501-682-0631 or e-mail at [meints@adeq.state.ar.us](mailto:meints@adeq.state.ar.us).

Sincerely,



René E. Meints  
Enforcement Analyst  
Water Enforcement Branch  
Water Division