

City of Berryville

Public Works Department

P.O. Box 227
305 East Madison
Berryville, Arkansas 72616

Office of the Director, Kirby Murray

Phone: 870-423-4074
Fax: 870-423-4501
E-mail: kirbymurray@gmail.com

March 28, 2016

Jacqueline Trotta
Enforcement Analyst
Water Division
Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, AR 72118
(501)682-0632


Dear Ms. Trotta:

This letter serves as the requested follow-up report regarding the partially treated effluent discharge at the Berryville WWTP, AFIN #08-00034 Permit #AR0021792.

At approximately 10:45 a.m. on 24 March, 2016, a mechanical failure in the UV disinfection system allowed approximately 591,600 gallons of partially treated effluent to discharge from the treatment facility. Investigative efforts revealed that a relay in the UV system failed causing the entire unit to automatically shut down in order to protect itself from further mechanical and electrical damage. This shut down allowed water to pass through the UV channel to the permitted Outfall 001 without receiving the disinfection portion of the treatment process. The discharged water during the shut down period received treatment from all treatment processes at the facility, except UV disinfection. Necessary repairs were completed and the UV system was placed back into operation at approximately 5:20 p.m. No adverse environmental impact has been observed and none is expected.

Please let me know if you have any questions or need additional information.

Sincerely,



Kirby Murray

C: Mayo Miller, CH2M

City of Berryville


P.O. BOX 227 - 305 E. MADISON

Berryville, Arkansas 72616

NORTHWEST AR PSDF

AR 227 1 L

29 MAR 2016 PM



JACQUELINE TROTTA
ENFORCEMENT ANALYST, WATER DIVISION
ADEQ
5301 NORTHSHORE DR
NORTH LITTLE ROCK, AR
72118

72118+5317

