



ARKANSAS
Department of Environmental Quality

September 27, 2011

Mr. Stanly Miller
Little Rock Wastewater – Adams Field WWTP
11 Clearwater Drive
Little Rock, AR 72204

RE: NPDES Permit Number AR0021806, AFIN 60-00409

Dear Mr. Miller:

A recent review of the NPDES file for Adams Field WWTP has revealed the following violations for the August 2011 Monitoring Period.

DISCHARGE NUMBER	PARAMETER	VIOLATION	LIMIT	UNITS
001-A	Fecal Coliform 30DA GEO	252	200	#/100ml
001-A	Fecal Coliform 30DA GEO	594	400	#/100ml

As you know, Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit require you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Please refer to NPDES Permit Number AR0021806 and AFIN 60-00409 in any written correspondence to ADEQ. Should you have any questions, feel free to contact me at 501-682-0632 or e-mail at bolenbaugh@adeq.state.ar.us.

Thank you,

Jason R. Bolenbaugh
Enforcement Analyst
Water Division Enforcement Branch

