

**LITTLE ROCK WATER RECLAMATION AUTHORITY  
SUMMARY OF SELF MONITORING DATA INVALIDATED BY QC PROTOCOL  
SUBMITTED WITH DISCHARGE MONITORING REPORT**

Adams Field Water Reclamation Facility

NPDES Permit Number AR0021806 - AFIN 60-00409

Month/Year: October / 2022

Flow Date	Error Type		Parameter(s) Affected	Reasons for Loss of Self Monitoring Data	Corrective Action(s) Taken	*LRWRA C.A.R. No.
	Laboratory	Sampling				
10/24/2022	X		CBOD	The GGA recovery did not meet acceptable QC criteria. The GGA had a recovery of 161.73 mg/L out of an acceptable range of 167.5 mg/L – 228.5 mg/L.	The LRWRA lab is conducting a study to investigate using Adams Field Primary Effluent CBOD results to calculate the seed correction for CBODs. A meeting with the Lab Administrator, Lab Coordinator, and the new QA Specialist will be set to implement this practice.	2022-013

\*A full Corrective Action Report (C.A.R.) is on file at Little Rock Water Reclamation Authority (LRWRA) and is available for review/submittal at any time.

In accordance with the certification statement found in the NPDES Permits issued to Little Rock Wastewater (Part II D. 11. c.): I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

*Rebecca Burkman*

Signature of Principal Executive Officer or Authorized Agent

11-18-22

Date

Greg Ramon  
Chief Executive Officer  
501-376-2903

Walter B. Collins, P.E.  
Director, Operations and Facilities  
501-688-1429

Eric Wassell  
Plant Superintendent  
501-490-5402

Rebecca Burkman  
Director of Environmental Affairs  
501-688-1486