


Little Rock Wastewater

October 22, 2013

Ryan Benefield, Water Division Chief
Water Division
Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, Arkansas 72118-5317



RE: NPDES Permit Number AR0021806,
Adams Field WWTP
Effluent Disinfection Equipment Failure

Dear Mr. Benefield;

The Adams Field Wastewater Treatment facility experienced a local power failure to the UV disinfection system on October 21, 2013 thru the night until the morning of October 22, 2013. The power failure occurred 11 times, for a total duration of 38 minutes. During the 38 minutes approximately 380,000 gallons of non-disinfected secondary effluent was discharged to the Arkansas River. The automatic sampler was not affected during this time period as this time is not a scheduled sampling time.

If you have any questions concerning this letter, or if we can provide additional information please contact me at 688-1483.

Sincerely,
LITTLE ROCK WASTEWATER UTILITY

Stanley Miller
Manager of Operations and Facilities

Cc: Reggie Corbitt, CEO
Stanly Suel, EAD Manager