



11 Clearwater Drive
 Phone: 501-376-2903
 Fax: 501-688-1409

Little Rock, Arkansas 72204
 Toll Free: 1-800-880-2903
 www.lrwu.com

December 30, 2015

Mr. Richard Healey
 Enforcement Branch Manager
 Arkansas Department of Environment Quality
 5301 N. Shore Drive
 North Little Rock, AR 72118

RECEIVED

DEC 30 2015

ml 2:45 pm

RE: Adams Field Wastewater Treatment Facility
 Wet Weather Peak Flow Blending
 NPDES Permit No. AR0021806 AFIN: 60-00409

Dear Mr. Healey:

The City of Little Rock received rainfall accumulations ranging between 3.99 inches to 7.03 inches across the twelve dedicated Little Rock Wastewater rain gauge stations during the event that occurred December 25th through December 28th. As a result, significant increases in collection system flows were experienced. Instantaneous peak influent flow rates prior to the blending reached as high as 90.34 MGD as the 13 MG on-site storage was filled. After the storage capacity at the Adams Field Equalization Basin and the off-site Peak Flow Attenuation Basin (30 MG) was exhausted, the diversion of wet weather flow around secondary treatment components was necessary.

Wet weather flows diverted around the secondary system (expressed as daily totals) are indicated in the following table:

<u>Flow Date</u>	<u>NPDES Effluent Flow*</u>	<u>Diverted Volume**</u>
12/28/2015	64.55 MGD	11.77 MG
12/29/2015	52.11 MGD	5.38 MG

* 24-hour period is 8:00 a.m. to 8:00 a.m. to match composite sample collection period


** 24-hour period is midnight to midnight

The flow diversion did not result in any effluent water quality violations with the total effluent flow receiving UV disinfection prior to discharge. LRW does not foresee any difficulties meeting the weekly or monthly permit limitations for December as a result of this flow diversion.

Should you have any questions concerning this notification, please give me a call at 501-688-1429 or by e-mail at walter.collins@lrwu.com.

Sincerely,

LITTLE ROCK WASTEWATER

A handwritten signature in black ink, appearing to read 'Walter B. Collins', written in a cursive style.

Walter B. Collins, P.E.
Director of Operations and Facilities

Cc: Greg Ramon, CEO
Howell Anderson, P.E., COO
Stanley Suel, Director of Environmental Assessment Department