



ARKANSAS ENERGY & ENVIRONMENT

March 16, 2021

Honorable Paige Chase
Mayor, City of Monticello
P.O. Box 505
Monticello, AR 71657

email: montmayor@att.net

RE: NPDES Permit Number AR0021831, AFIN 22-00379
Permitted Effluent Limitation Violations

Dear Mayor Chase,

A review of recent Discharge Monitoring Reports (DMRs) for the above-mentioned facility revealed the following compliance issues:

The facility has reported 4 violations of Part I, Section A of NPDES Permit No. AR0021831 during the review period. DEQ requires the City of Monticello to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0664, or you may e-mail me at Sarah.Pierce@adeq.state.ar.us.

Sincerely,

Sarah Pierce
Enforcement Analyst
Office of Water Quality, Enforcement Branch

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio	Violation Code	Parameter Code
02/28/2019	001-A	Discharge flow as % of stream flow, DAILY MX, %	78	78.1	0%	E90	01352-P-1
12/31/2018	001-A	Discharge flow as % of stream flow, DAILY MX, %	78	78.1	0%	E90	01352-P-1
03/31/2018	001-A	Discharge flow as % of stream flow, DAILY MX, %	78	78.1	0%	E90	01352-P-1
03/31/2018	001-A	Coliform, fecal general, 7 DA GEO, #/100mL	2000	2194	10%	E90	74055-1-0