

City of Eureka Springs
Public Works Dept.

Jay Wilson Director
3174 E. Van Buren
Eureka Springs, AR 72632
Phone: 479-253-9600
Fax: 479-253-6974
Email: jwilson@cityofeurekasprings.org

POST
NOV 06 2007
MARKED

Mr. Gene Little
Enforcement Administrator
Water Division Enforcement Section, ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

Re: NPDES Permit Number AR0021865, AFIN 08-0036, CAO LIS NO. 07-100
Comprehensive Plan w/ Milestone Schedule

Dear Mr. Little;

In accordance with the above referenced Consent Administrative Order LIS No. 07-100, we are hereby submitting our Comprehensive Plan with Milestone Schedule to address effluent violations pursuant to paragraphs 1 and 2 in Order and Agreement Section.

The effluent violations include the following parameters and permit limits:


CBOD5	10 / 15	
TSS	15 / 23	
NH3-N	2.5 / 3.8 (May-Oct)	5 / 7.5 (Nov-Apr)
DO	6.5	
FCB	200 / 400	
NO3 + NO2-N	10 / 15	

The new wastewater treatment plant is expected to be substantially complete by December 31, 2007. The plant design will meet all effluent permit limits as stated above and is expected to be fully functional and in compliance meeting permit limits by April 30, 2008. *compliance - 5/14/08 - Arin*

The new plant is designed for an average daily flow of 0.90 MGD with an instantaneous peak flow of 3.25 MGD, which is substantially greater than the existing treatment facility, however, until peak flows in the collection system are under control, there will exist a potential for future non-compliance during high flow events in wet weather seasons.

We trust this response will comply with the Consent Administrative Order referenced above for the effluent violations. If you need further information, or have any questions, please give me a call at 479-253-9600.

Sincerely,



Jay Wilson

Public Works Director