

Thomas Harrington (adpce.ad)

From: Terry Long <eswwtp@yahoo.com>
Sent: Monday, September 25, 2023 3:34 PM
To: Thomas Harrington (adpce.ad); Richard Healey (adpce.ad); Leslie Allen-Daniel (adpce.ad)
Cc: Simon Wiley
Subject: Update AR0021865

Follow Up Flag: Follow up
Flag Status: Flagged

Mr. Harrington,

I am pleased to let you know that we survived the weekend with ZERO overflow events. At this time, the plant appears to be running well, with the mixed liquor suspended solids settling very good, resulting in clear discharges to our receiving stream.

Concerning the progress being made towards repairs, I am disappointed to say that no advances have been made, as we are still waiting on a quote from the local representative for the manufacturer of the defective valve to provide a quote to replace the valve. I was in contact with them this morning expressing the need to get the quote as soon as possible because other repairs were on hold until the valve can be replaced.

I do have an update on the plant upset report # **f095f2cf-2e47-44b8-b9b7-1af8102af322** that was concerning an issue with the blower for SBR#1 that was submitted 9/13/2023. The breaker has been received and installed. This resulting in discovering that the motor for the blower for SBR#1 is defective and requires repair or replacement. We have requested a quote for a new motor and basked to be put on their schedule for repair.

I will provide you with another update on Wednesday September 27.

If you have any questions or require additional information, please feel free to contact me.

Thank you,

Terry Long, Plant Manager
Eureka Springs WWTP
100 Highway 23 N.
Eureka Springs, AR 72632
479-253-7410 - Office
479-738-7035 - Cell
479-253-6974 - Fax
eswwtp@yahoo.com

Eureka Springs WWTP
Eureka Springs Public Works Dept.
3174 E. Van Buren
Eureka Springs, AR 72632
479-253-9600 - Office
479-253-6974 - Fax