

Thomas Harrington (adpce.ad)

From: Terry Long <eswwtp@yahoo.com>
Sent: Monday, October 2, 2023 3:16 PM
To: Thomas Harrington (adpce.ad); Richard Healey (adpce.ad); Leslie Allen-Daniel (adpce.ad)
Subject: AR 0021865 Update

Mr. Harrington,

Following is the update from the Eureka Springs wastewater treatment plant for Monday October 2, 2023.

The effluent continues to look good, being clear and containing only very few, if any, solids or discoloration. When caught in a clear container, the effluent is clear with the only solids being visible, are those which appear to be very small pieces of floc which failed to form a clump large enough to settle out.

Concerning the status of the motive pump for SBR#1, as I stated in my last update, we have located a replacement for the defective valve and at this time, we are in a holding pattern, waiting to find out from the service technicians if they are going to have time to install the valve this week or if it will be next week.

Concerning the status of the blower for SBR#1, unfortunately there hasn't been a lot of movement or change in status. I have been in contact with the manufacturer of the blower to discuss any possible issues that the blower might have that led to the motor burning up and at this time, it does not appear that the blower has any effect on the motor failure.

We have had no incidents or problems since my last report.

I hope and trust that I have provided all the information requested and needed. If you require any additional information, please feel free to reach out and I will provide that as quickly as possible. I have made a note to continue to update you with the progress being made and I will submit another report to you on Wednesday October 4, 2023.

Thank you,

Terry Long, Plant Manager
Eureka Springs WWTP
100 Highway 23 N.
Eureka Springs, AR 72632
479-253-7410 - Office
479-738-7035 - Cell
479-253-6974 - Fax
eswwtp@yahoo.com

Eureka Springs WWTP
Eureka Springs Public Works Dept.
3174 E. Van Buren
Eureka Springs, AR 72632
479-253-9600 - Office
479-253-6974 - Fax