

**From:** [Dwayne Allen](#)  
**To:** [Pemberton, Layne](#)  
**Subject:** 0021865  
**Date:** Thursday, September 17, 2015 5:13:23 PM

---

Layne, Just updating you on our pump situation. We have had issues with the motive pump on #2 since late July. We had it back in service and had been limping it along, it till 09/01/2015, when the bearings arrived and it was taken off line. The shaft had enough wear to be replaced. We hope to be back on line next week. That still puts us over three weeks without wasting # 2. We have had only nutrient issues but now we have had to adjust our tank levels, as we have begun to have solid concerns. I will keep you up to date and if there any further delays we may have to run with one basin and declare an upset. The large pump replacement parts are very expensive and have seemed not to warrant stocking. I have tried to have a distributor stock them , but they still come from Fairbanks Morris. I will let you know as soon as we are back online or if there are any changes.

*DAllen*

Director of Public Works  
3174 East Van Buren  
Eureka Springs, AR 72632-9498  
(479) 253-8868  
Fax (479) 253-6974