

City of Eureka Springs Compliance Report

AR0021865

Month July

Year 2017

Type of Violation	Permit Limit	Permit Violation	Dates of Violation	Cause of Violation
7 DAY-AVG NH3	3.8	7.6	07/19/2017	Equipment
7 DAY-AVG NH3	3.8	9.8	07/26/2017	Equipment
30 DAY AVG NH3	2.5	6.9	07/2017	Equipment
30 DAY LOADING AVG	18.8	21.3	07/2017	Equipment

We discovered impeller damage on the Motive Pump for Basin One. Repaired impeller will last till our ordered replacement arrives. I have approved the purchase of a complete set of spare repair parts for these pumps as they are the heart of our operation.

I certify under penalty of law that I have personally examined the information submitted herein: and based on my inquiry of those individuals immediately responsible for obtaining the information; I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. 18 U.S.C. 1001 and 33 U.S.C 1319 (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and five years.)

Signature of Cognizant or Ranking Official



Date

08/24/2017