

City of Eureka Springs

Public Works Department
3174 East Van Buren Street
Eureka Springs, Arkansas 72632 -9498

Office of the Director, Dwayne Allen

Phone: 479-253-9600
Fax: 479-253-6974
e-mail: dallen@cityofeurekasprings.org

August 20, 2018

ADEQ Water Division
Att. Layne Pemberton
5301 Northshore Drive
North Little Rock, AR 72118-5317

Re: Nutrient Overage

Mr. Pemberton:

The City of Eureka Springs Wastewater Facility had a communication card fail on May 26, 2018, which resulted in the Plant being run manually until May 29, 2018. This resulted in the timing of the batch reactors being off during our peak season. This coupled with the extreme heat and increased biomass activity upset our nitrogen cycle. We had the card replaced, and now keep spares. We are taking RFQs to replace the hardware and update the software on our control system this year.

We have returned to the correct timings and believe we will be in total compliance this month. If we have any daily exceedances, I will call you.

If you have any questions or require any further information, please let me know.

Sincerely,



Dwayne Allen
Public Works Director