Thomas Harrington (adpce.ad)

From:	Terry Long <eswwtp@yahoo.com></eswwtp@yahoo.com>
Sent:	Wednesday, September 27, 2023 3:49 PM
То:	Thomas Harrington (adpce.ad); Richard Healey (adpce.ad); Leslie Allen-Daniel (adpce.ad)
Subject:	AR 0021865 Update

Mr. Harrington,

I am pleased to report that the effluent discharges from our treatment plant continue to look good.

The issue that we were having last week with our pressure transducers not communicating properly has been identified and corrected. There was a bad connection between the transducer and the plant wiring resulting in faulty pressure readings being reported which resulted in improper water levels being picked up by the control system for the plant.

Concerning the actions that are required to repair the motive pump on SBR#!, we recieved the quote for replacing the defective valve and are in the process of getting the people scheduled to come in to change out the valve. We are now in the process of getting the people scheduled in to replace the valve.

Concerning the defective blower for SBR#1, we are still waiting on a quote for a replacement motor.

I hope and trust that I have provided all the information you requested and need. If you require any additional information, please feel free to reach out and I will provide that was quickly as possible. I have made a note to continue to update you with the progress being made and I will submit another report to you on Friday September 29, 2023

Thank you,

Terry Long, Plant Manager Eureka Springs WWTP 100 Highway 23 N. Eureka Springs, AR 72632 479-253-7410 - Office 479-738-7035 - Cell 479-253-6974 - Fax eswwtp@yahoo.com

Eureka Springs WWTP Eureka Springs Public Works Dept. 3174 E. Van Buren Eureka Springs, AR 72632 479-253-9600 - Office 479-253-6974 - Fax