

Thomas Harrington (adpce.ad)

From: Terry Long <eswwtp@yahoo.com>
Sent: Friday, October 6, 2023 3:37 PM
To: Thomas Harrington (adpce.ad); Richard Healey (adpce.ad); Leslie Allen-Daniel (adpce.ad)
Cc: Simon Wiley
Subject: AR0021865 Update

Mr. Harrington,

Following is the update from the Eureka Springs wastewater treatment plant for Friday October 6, 2023.

The effluent continues to look good, being clear and containing only very few solids particles with little to no discoloration.

Concerning the status of the motive pump for SBR#1, as stated in my last two updates, we have located a replacement for the defective valve. One of the service technicians that will installing the valve came this morning and verified that the replacement valve will fit without any problem. The entire service team is still scheduled to arrive here on the morning of Thursday October 12 to perform the valve changeout

Concerning the status of the blower for SBR#1, as mentioned in the last update a replacement blower unit has been located and is scheduled to arrive the middle of next week. When the existing blower unit is removed it will be shipped to the manufacturer to be rebuilt and placed in our inventory as a spare.. Unfortunately there hasn't been any movement or change in status of the electric motor for the blower, as we are still waiting to get pricing and availability on a new motor as well as the estimated time and cost to have the existing motor rebuilt. hear if the motor can be rebuilt or if it will have to be replaced. .

We have had no incidents or problems since my last report.

I hope and trust that I have provided all the information requested and needed. If you require any additional information, please feel free to reach out and I will provide that as quickly as possible. I have made a note to continue to update you with the progress being made and I will submit another report to you on Monday October 9, 2023.

Thank you,

Terry Long, Plant Manager
Eureka Springs WWTP
100 Highway 23 N.
Eureka Springs, AR 72632
479-253-7410 - Office
479-738-7035 - Cell
479-253-6974 - Fax
eswwtp@yahoo.com

Eureka Springs WWTP
Eureka Springs Public Works Dept.
3174 E. Van Buren
Eureka Springs, AR 72632
479-253-9600 - Office
479-253-6974 - Fax