

## Thomas Harrington (adpce.ad)

---

**From:** Terry Long <eswwtp@yahoo.com>  
**Sent:** Monday, October 9, 2023 3:13 PM  
**To:** Thomas Harrington (adpce.ad); Richard Healey (adpce.ad); Leslie Allen-Daniel (adpce.ad)  
**Subject:** AR 0021865 Update

Mr. Harrington,

Following is the update from the Eureka Springs wastewater treatment plant for Monday October 9, 2023.

The effluent continues to look good, being clear and containing only very few solids particles with little to no discoloration.

Concerning the status of the motive pump for SBR#1, as stated in my previous updates, we have located a replacement for the defective 12-inch valve, with that replacement still scheduled for Thursday October 12, 2023. On Wednesday morning SBR#1 will be taken off-line and we will begin the process of draining the basin down to a level that will prevent flooding the pump room when the defective valve is removed.

Concerning the status of the blower for SBR#1, there has been no change or movement as we have located a new blower and have scheduled the replacement for the middle of this week. We are still planning to ship the existing blower back to the manufacturer to be rebuilt and then placed in our inventory as a spare. Unfortunately there hasn't been any movement or change in status of the electric motor for the blower, as we are still waiting to get pricing and availability on a new motor as well as the estimated time and cost to have the existing motor rebuilt. hear if the motor can be rebuilt or if it will have to be replaced. .

We have had no incidents or problems since my last report.

I hope and trust that I have provided all the information requested and needed. If you require any additional information, please feel free to reach out and I will provide that as quickly as possible. I have made a note to continue to update you with the progress being made and I will submit another report to you on Wednesday October 11, 2023.

Thank you,

Terry Long, Plant Manager  
Eureka Springs WWTP  
100 Highway 23 N.  
Eureka Springs, AR 72632  
479-253-7410 - Office  
479-738-7035 - Cell  
479-253-6974 - Fax  
eswwtp@yahoo.com

Eureka Springs WWTP  
Eureka Springs Public Works Dept.  
3174 E. Van Buren  
Eureka Springs, AR 72632  
479-253-9600 - Office  
479-253-6974 - Fax