

## Thomas Harrington (adpce.ad)

---

**From:** Terry Long <eswwtp@yahoo.com>  
**Sent:** Wednesday, October 25, 2023 8:44 PM  
**To:** Thomas Harrington (adpce.ad); Richard Healey (adpce.ad); Leslie Allen-Daniel (adpce.ad)  
**Cc:** Simon Wiley  
**Subject:** AR 0021865 Update

Mr. Harrington,

Following is the update from the Eureka Springs wastewater treatment plant for Wednesday October 25, .2023.

The effluent continues to look good, being clear and containing only very few solids particles with little to no discoloration.

Concerning the status of the motive pump for SBR#1, as previously stated when we removed the pump, it was very evident that the shaft was bent. We are waiting on an official report detailing the list (with pricing & availability) of bearings and seals that will need to be replaced,, but we know that we will have to replace the shaft and at least one bearing and seal. We also requested a quote to replace the pump. We have asked that the repair shop do whatever they can to expedite the repairs of the pump as well as obtaining a quote for replacement..

Concerning the status of the UV disinfection unit, as previously stated after speaking with a field service technician for the manufacturer of the UV system, we have ordered UV bulbs and quartz sleeves on order, as well as a new DCA assembly and are currently awaiting delivery so we can install the DCA assembly and replace UV bulbs with the DCA assembly expected to arrive by Thursday and the bulbs and sleeves arriving hopefully Friday. We continue to follow our new SOP for SSOs at the wastewater treatment plant including notification of residents living downstream from the treatment plant as well as the general public and encouraging people to follow our Facebook page for further updates. We continue to collect and analyze samples taken from eight (8) locations along Leatherwood Creek at a minimum of every three calendar days to monitor the e. coli level in the creek.

Since my last report we have had no issues with solids being washed out of the plant or discolored discharges.

I hope and trust that I have provided all the information requested and needed. If you require any additional information, please feel free to reach out and I will provide that as quickly as possible. I have made a note to continue to update you with the progress being made and I will submit another report to you on Friday October 27, 2023.

Thank you,

Terry Long, Plant Manager  
Eureka Springs WWTP  
100 Highway 23 N.  
Eureka Springs, AR 72632  
479-253-7410 - Office  
479-738-7035 - Cell  
479-253-6974 - Fax  
eswwtp@yahoo.com

Eureka Springs WWTP  
Eureka Springs Public Works Dept.  
3174 E. Van Buren  
Eureka Springs, AR 72632  
479-253-9600 - Office  
479-253-6974 - Fax