

Thomas Harrington (adpce.ad)

From: Terry Long <eswwtp@yahoo.com>
Sent: Wednesday, October 4, 2023 3:30 PM
To: Thomas Harrington (adpce.ad); Richard Healey (adpce.ad); Leslie Allen-Daniel (adpce.ad)
Cc: Simon Wiley
Subject: AR0021865 Update

Mr. Harrington,

Following is the update from the Eureka Springs wastewater treatment plant for Wednesday October 4, 2023.

The effluent continues to look good, being clear and containing only very few solids with no discoloration. When caught in a clear container, the effluent is clear with the only solids being visible are those which are very small pieces of pin-floc which failed to form a clump large enough to settle out.

Concerning the status of the motive pump for SBR#1, as stated in my last update, we have located a replacement for the defective valve. This morning we were able to schedule the installation of the new valve for next week. At this time, we have scheduled one of the service technicians to come in this Friday October 6 to visually verify that the replacement valve will fit properly and also determine what, if any, specialized equipment will be required to replace the valve. We also have the entire service team scheduled to come in on Thursday October 12 to perform the valve changeout

Concerning the status of the blower for SBR#1, a replacement blower unit has been located and placed on order with delivery the middle of next week. When the existing blower unit is removed it will be shipped to the manufacturer to be rebuilt and placed in our inventory as a spare.. Unfortunately there hasn't been any movement or change in status of the electric motor for the blower, as we are still waiting to hear if the motor can be rebuilt or if it will have to be replaced. .

We have had no incidents or problems since my last report.

I hope and trust that I have provided all the information requested and needed. If you require any additional information, please feel free to reach out and I will provide that as quickly as possible. I have made a note to continue to update you with the progress being made and I will submit another report to you on Friday October 6, 2023.

Thank you,

Terry Long, Plant Manager
Eureka Springs WWTP
100 Highway 23 N.
Eureka Springs, AR 72632
479-253-7410 - Office
479-738-7035 - Cell
479-253-6974 - Fax
eswwtp@yahoo.com

Eureka Springs WWTP
Eureka Springs Public Works Dept.
3174 E. Van Buren
Eureka Springs, AR 72632
479-253-9600 - Office
479-253-6974 - Fax