

Thomas Harrington (adpce.ad)

From: Terry Long <eswwtp@yahoo.com>
Sent: Wednesday, November 8, 2023 3:28 PM
To: Thomas Harrington (adpce.ad); Richard Healey (adpce.ad); Leslie Allen-Daniel (adpce.ad)
Cc: Simon Wiley; Zane Lewis; Spencer Briggs
Subject: AR 0021865 Update

Mr. Harrington,

Following is the update from the Eureka Springs wastewater treatment plant for Wednesday November 6, .2023.

The effluent continues to look good, being clear and containing only very few solids particles with little to no discoloration.

Concerning the status of the motive pump for SBR#1, unfortunately there has been no progress made. As previously stated the shaft was obviously bent when the pump was removed. We are still waiting for the complete list of necessary parts so they can be ordered. A new pump has been ordered and when repaired, the old pump will be placed in spare parts inventory.

Concerning the status of the UV disinfection unit, there has been no progress made as we are waiting on new LCA assemblies to arrive from the factory. We are speaking with a field service technician after replacing each item to let him know the status and to make recommendations as to what we need to do next. Thus far we have replaced all of the quartz sleeves and bulbs, one DCA assembly, as well as several of the liquid tight strain relief fittings. We continue to follow our new SOP for SSOs at the wastewater treatment plant including notification of residents living downstream from the treatment plant as well as the general public and encouraging people to follow our Facebook page for further updates. We continue to collect and analyze samples taken from eight (8) locations along Leatherwood Creek at a minimum of every three calendar days to monitor the e. coli level in the creek.

Concerning the status of the influent valve for SBR#1, the valve is still inoperable, but a replacement actuator was ordered today with expedited shipping. As a result of the valve being inoperable, SBR#1 remains offline to avoid the possibility of an overflow occurring because the influent valve failed to operate. A quote for a replacement nut has been requested and SBR#1 taken off line to prevent it from overflowing. The result of taking SBR#1 offline is that all wastewater will be treated in one basin, which is possible, although not the preferred method.

The installation of new wireless security cameras at the wastewater treatment plant has been completed and they are working great.

Since my last report we have had no issues with solids being washed out of the plant or discolored discharges.

I hope and trust that I have provided all the information requested and needed. If you require any additional information, please feel free to reach out and I will provide that as quickly as possible. I have made a note to continue to update you with the progress being made and I will submit another report to you on Friday November 10, 2023.

Thank you,

Terry Long, Plant Manager
Eureka Springs WWTP
100 Highway 23 N.
Eureka Springs, AR 72632
479-253-7410 - Office
479-738-7035 - Cell
479-253-6974 - Fax
eswwtp@yahoo.com

Eureka Springs WWTP
Eureka Springs Public Works Dept.
3174 E. Van Buren
Eureka Springs, AR 72632
479-253-9600 - Office
479-253-6974 - Fax