

Thomas Harrington (adpce.ad)

From: Terry Long <eswwtp@yahoo.com>
Sent: Friday, November 17, 2023 3:27 PM
To: Thomas Harrington (adpce.ad); Richard Healey (adpce.ad); Leslie Allen-Daniel (adpce.ad)
Cc: Simon Wiley; Zane Lewis; Spencer Briggs
Subject: AR 0021865 Update - Nov 17 2023

Mr. Harrington,

Following is the update from the Eureka Springs wastewater treatment plant for Friday November 17, .2023.

The effluent continues to look good, being clear and containing only very few solids particles with little to no discoloration.

Concerning the status of the motive pump for SBR#1, unfortunately there has been no progress made. As previously stated, we have ordered a new pump and authorized the repairs of our old pump and are waiting for one of them to arrive so it can be installed and SBR#1 put fully back on-line.

Concerning the status of the UV disinfection unit, progress is being made slowly. We have all new bulbs in both of our UV modules, a new DCA assembly in one module and a new LCA assembly in the other module. One module is operational, but we are not getting power to the bulbs in the other module even though we are getting power to the module. We continue to speak with a field service technician after replacing each item to let him know the status and to make recommendations as to what we need to do next. We are still following our new SOP for SSOs at the wastewater treatment plant including notification of residents living downstream from the treatment plant as well as the general public and encouraging people to follow our Facebook page for further updates. We continue to collect and analyze samples taken from eight (8) locations along Leatherwood Creek at a minimum of every three calendar days to monitor the e. coli level in the creek, although on two consecutive sampling days the E. coli count in our effluent has been 10 colonies per 100 ml.

Concerning the status of the influent valve for SBR#1, the defective actuator was replaced today and the influent valve is back fully functional again.

Since my last report we have had no issues with solids being washed out of the plant or discolored discharges.

I hope and trust that I have provided all the information requested and needed. If you require any additional information, please feel free to reach out and I will provide that as quickly as possible. I have made a note to continue to update you with the progress being made and I will submit another report to you on Monday November 20, 2023.

Thank you,

Terry Long, Plant Manager
Eureka Springs WWTP
100 Highway 23 N.
Eureka Springs, AR 72632
479-253-7410 - Office
479-738-7035 - Cell
479-253-6974 - Fax
eswwtp@yahoo.com

Eureka Springs WWTP
Eureka Springs Public Works Dept.
3174 E. Van Buren

Eureka Springs, AR 72632
479-253-9600 - Office
479-253-6974 - Fax