

Thomas Harrington (adpce.ad)

From: Terry Long <eswwtp@yahoo.com>
Sent: Friday, December 15, 2023 3:57 PM
To: Thomas Harrington (adpce.ad); Richard Healey (adpce.ad); Leslie Allen-Daniel (adpce.ad)
Cc: Simon Wiley; Zane Lewis; Spencer Briggs
Subject: AR 0021865 Update - December 15, 2023

Mr. Harrington,

Following is the update from the Eureka Springs wastewater treatment plant for Friday December 15, 2023.

The effluent continues to look good, being clear and containing only very few solids particles with little to no discoloration.

Concerning the status of SBR#1, this basin is now fully operational. The rebuilt Fairbanks Morse motive pump was received and installed on Monday. Additionally, the new Fairbanks Morse motive pump was received and placed in our spare parts inventory.

Concerning the status of the UV disinfection unit, progress continues to be slow. Both UV modules are still working after the installation of new DCA assemblies. We are still having a communication issue between the control panel and one of the UV modules, but we are continuing to attempt to identify and eliminate the problem. We have been speaking to a field service technician to let him know the status and to make recommendations as to what we need to do next. We are still following our new SOP for SSOs at the wastewater treatment plant including notification of residents living downstream from the treatment plant as well as the general public and encouraging people to follow our Facebook page for further updates.

Since my last report we have had no issues with solids being washed out of the plant or discolored discharges.

I hope and trust that I have provided all the information that was requested and needed. If you require any additional information, please feel free to reach out and I will provide that as quickly as possible. I have made a note to continue to update you with the progress being made and I will submit another report to you on Friday December 22, 2023.

Thank you,

Terry Long, Plant Manager
Eureka Springs WWTP
100 Highway 23 N.
Eureka Springs, AR 72632
479-253-7410 - Office
479-738-7035 - Cell
479-253-6974 - Fax
eswwtp@yahoo.com

Eureka Springs WWTP
Eureka Springs Public Works Dept.
3174 E. Van Buren
Eureka Springs, AR 72632
479-253-9600 - Office

