

City of Eureka Springs Compliance Report

AR0021865

Month July

Year 2018

Type of Violation	Permit Limit	Permit Violation	Dates of Violation	Cause of Violation
7 DAY-AVG NH3	3.8	6.4	07/11/18	CONTROL
7 DAY-AVG NH3	3.8	8.6	07/18/18	CONTROL
7 DAY-AVG NH3	3.8	7.5	07/25/18	CONTROL
MO-AVG NH3	2.5	7.5	06/18	CONTROL
MO-AVG CON NH3	22.7	23.6	06/18	CONTROL

The plant experienced a communications card failure and was placed into manual operation. This affected the timing of the Sequencing Batch Reactors which resulted in upsetting the biological nitrification cycle. I send a letter reporting last months upset and update our status this month.

I certify under penalty of law that I have personally examined the information submitted herein: and based on my inquiry of those individuals immediately responsible for obtaining the information; I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. 18 U.S.C. 1001 and 33 U.S.C 1319 (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and five years.)

Signature of Cognizant or Ranking Official _____ Date _____