

City of Eureka Springs Compliance Report

AR0021865

Month June


Year 2019

Type of Violation	Permit Limit	Permit Violation	Dates of Violation	Cause of Violation
7 DAY-AVG NH3	3.8	12.1	06/05/19	MLSS
MO-AVG NH3	2.5	4.8	06/19	MLSS

The plant had a NH3 sample spike. With the heat and this being the time of year our influent peaks our MLSS became too high. By increasing the wasting it came back into compliance.

I certify under penalty of law that I have personally examined the information submitted herein: and based on my inquiry of those individuals immediately responsible for obtaining the information; I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. 18 U.S.C. 1001 and 33 U.S.C 1319 (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and five years.)

Signature of Cognizant or Ranking Official



Date

07/25/19