

City of Eureka Springs Compliance Report

AR0021865

Month June


Year 2020

Type of Violation	Permit Limit	Permit Violation	Dates of Violation	Cause of Violation
Fecal 7-day-geo	400	1986	06/24/2020	Bulbs

Replaced bulbs on the Aquaray UV system to restore compliance. Ordering a new set of lamps.

I certify under penalty of law that I have personally examined the information submitted herein: and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. 18 U.S.C. 1001 and 33 U.S.C 1319 (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and five years.)

Signature of Cognizant or Ranking Official



Date

07-21-2020