

Kristen Graham (adpce.ad)

From: Simon Wiley <swiley@eurekaspringsar.gov>
Sent: Wednesday, April 19, 2023 9:44 AM
To: Kristen Graham (adpce.ad)
Cc: Rob Mullins; Linda Schumpert; Butch Berry; Kim Stryker; Michael Akins; Carroll Boone
Subject: Water Leak AR0021865

Kristen,

Thank you for taking my call this morning.

This morning at 6am we had an 8-inch water main that ruptured and caused a fairly massive leak. This leak drained our East Mountain Tank to 7.5-feet (Full is approx. 68-feet). We had the leaking section isolated by 7:45am and the tank is currently refilling. I have Barrows Excavation from Berryville, AR onsite repairing the broken main which I assume will be completed no later than the end of business today.

Could you advise us as to what steps we need to make from here?

Thanks,

Simon Wiley, CPM

Director of Public Works

City of Eureka Springs, Arkansas

3174 East Van Buren

Eureka Springs, AR 72632

P: 479.253.9600

swiley@eurekaspringsar.gov

“Unless someone like you cares a whole awful lot, nothing is going to get better. It’s not.” – **Dr. Seuss**