

# City of Eureka Springs Compliance Report

AR0021865

Month April


Year 2015

Type of Violation	Permit Limit	Permit Violation	Dates of Violation	Cause of Violation
MO-AVG NH3	3.9	4.6	04/2015	Chemical feed
7 DAY-AVG NH3	3.9	7.3	04/15/2015	Chemical feed
7 DAY-AVG NH3	3.9	6.2	04/22/2015	Chemical feed

Warm weather settings and the reduced permit numbers caused our increased ammonia nitrogen level. Have increased feed rate and we are back in compliance.

I certify under penalty of law that I have personally examined the information submitted herein: and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. 18 U.S.C. 1001 and 33 U.S.C 1319 (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)

Signature of Cognizant or Ranking Official




Date

05/22/2015

City of Eureka Springs  
Department of Public Works  
3174 East Van Buren  
Eureka Springs, AR 72632-9498

**CERTIFIED MAIL™**



7009 1410 0002 0698 6139



UNITED STATES  
POSTAL SERVICE

1000



72118

U.S. POSTAGE  
PAID  
EUREKA SPRINGS, AR  
72632  
MAY 27, 15  
AMOUNT

**\$4.49**  
00047533-02

ADEQ Water Division  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

