

# City of Eureka Springs Compliance Report

AR0021865

Month August


Year 2012

Type of Violation	Permit Limit	Permit Violation	Dates of Violation	Cause of Violation
MO-AVG	1.0	PO4- 1.5	08/2012	Chemical Feed

We have begun to feed alum slowly increasing the dosage to achieve 1 mg/l. We had over fed alum, saturating our mixed liquor and had stopped the alum feed on engineer's advice. We are also inducing caustic soda to increase out PH.

I certify under penalty of law that I have personally examined the information submitted herein: and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. 18 U.S.C. 1001 and 33 U.S.C 1319 (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)

Signature of Cognizant or Ranking Official



Date


09-24-2012

City of Eureka Springs  
Department of Public Works  
3174 East Van Buren  
Eureka Springs, AR 72632-9498

**CERTIFIED MAIL™**



7009 1410 0002 0698 5569



1000

72118

U.S. POSTAGE  
PAID  
BERRYVILLE, AR  
72616  
SEP 25, 12  
AMOUNT

**\$4.25**

00086367-06

ADEQ- Water Permits  
5301 Northshore Drive  
N. Little Rock, AR 72118-5317

