

# City of Eureka Springs Compliance Report

AR0021865

Month August


Year 2014

Type of Violation	Permit Limit	Permit Violation	Dates of Violation	Cause of Violation
MO-AVG PO4	1.0	2.0	08/2014	alkalinity
7 DAY-AVG PO4	2.0	2.5	08/13/2014	alkalinity
7 DAY-AVG NH3	3.8	4.3	08/06/2014	alkalinity

We had to preform repairs to our head works and when we put the effluent wet well back on line we had a large nutrient load. Our staff recorded an effluent NH3 reading of almost 50 mg/l at one point. The readings have been decreasing each test period. I have asked for an increase in chemical addition.

I certify under penalty of law that I have personally examined the information submitted herein: and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. 18 U.S.C. 1001 and 33 U.S.C 1319 (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)


Signature of Cognizant or Ranking Official



Date

09-22-14

City of Eureka Springs  
Department of Public Works  
3174 E. Van Buren  
Eureka Springs, AR 72632-9498



ADEQ Water Division  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

