

# City of Eureka Springs Compliance Report

AR0021865

Month August

Year 2015

Type of Violation	Permit Limit	Permit Violation	Dates of Violation	Cause of Violation
MO-AVG NH3	2.5	8.8	08/2015	Equipment
7 DAY-AVG NH3	3.8	9.7	08/05/2015	Equipment
7 DAY-AVG NH3	3.8	9.4	08/12/2015	Equipment
7 DAY-AVG NH3	3.8	7.3	08/19/2015	Equipment
MO-AVG-Loading NH3	18.8	34.1	08/2015	Equipment

We have just placed motive pump # two back on line and will reduce our mixed liquor as quickly as possible. I am making every effort to make sure we do not experience equipment failures to this extent again. We are refining our Correction Action Plan. Unable to mix or waste for thirty days.


I certify under penalty of law that I have personally examined the information submitted herein: and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. 18 U.S.C. 1001 and 33 U.S.C 1319 (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)

Signature of Cognizant or Ranking Official

Date

09/25/2015

City of Eureka Springs  
Department of Public Works  
3174 East Van Buren  
Eureka Springs, AR 72616-9201



ADEQ-Water Permits  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

