

City of Eureka Springs Compliance Report

AR0021865

Month January

Year 2014

Type of Violation	Permit Limit	Permit Violation	Dates of Violation	Cause of Violation
7 DAY-AVG NH3	7.5	15.5	01/22/2014	Weather
7 DAY AVG BOD	15.0	38.0	01/22/2014	Lab

The weather was very cold and the nitrogen numbers could be correct but we have disputed the BOD numbers our lab posted. They posted our influent as less than 2.0 mg/l which is what our effluent was and is still running. We paid the cost of extra sampling to make sure we were complaint. In my opinion the lab should have discounted the 01/22/2014 samples.

I certify under penalty of law that I have personally examined the information submitted herein: and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. 18 U.S.C. 1001 and 33 U.S.C 1319 (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)

Signature of Cognizant or Ranking Official

Date

02-24-2014

City of Eureka Springs
Department of Public Works
3174 East Van Buren
Eureka Springs, AR 72632-9498



ADEQ Water Permits
5301 Northshore Drive
N. Little Rock, AR 72118-5317

