

City of Eureka Springs Compliance Report

AR0021865

Month July

Year 2015

Type of Violation	Permit Limit	Permit Violation	Dates of Violation	Cause of Violation
7 DAY-AVG NH3	3.8	4.2	07/22/ 2015	Equipment
7 DAY-AVG NH3	3.8	13.2	07/29/ 2015	Equipment
MO-AVG NH3	2.5	6.6	06/2015	Equipment
MO-AVG# NH3	18.8	32.8	06/2015	Equipment

Our motive pump on # two went down this month, could not mix or waste. Our mixed liquor spiked and as the numbers show NO3 down and NH3 up, we are not achieving complete denitrification. We have the pump back on line, while waiting on bearings. We have been and will continue to make every effort to bring our nitrogen levels back in line.

I certify under penalty of law that I have personally examined the information submitted herein: and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. 18 U.S.C. 1001 and 33 U.S.C 1319 (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)


Signature of Cognizant or Ranking Official

Date

8-25-15

City of Eureka Springs
Department of Public Works
3174 East Van Buren
Eureka Springs, AR 72616-9201


CERTIFIED MAIL®



7015 0640 0004 2398 0029



1000



72118

U.S. POSTAGE
PAID
EUREKA SPRINGS, AR
72632
AUG 26, 15
AMOUNT

\$4.65

R2305E123300-02

ADEQ-Water Permits
5301 Northshore Drive
North Little Rock, AR 72118-5317