

City of Eureka Springs Compliance Report

AR0021865

Month June

Year 2012

Type of Violation	Permit Limit	Permit Violation	Dates of Violation	Cause of Violation
MO-Avg	1.0	PO4- 1.6	06/2012	Settings

Changed settings to maximize PO4 biological removal on advice of engineers and manufacture, have returned to previous setting as we lost our anoxic fill and experienced an across the board change.

I certify under penalty of law that I have personally examined the information submitted herein: and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. 18 U.S.C. 1001 and 33 U.S.C 1319 (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)

Signature of Cognizant or Ranking Official



Date

07-23-2012