

City of Eureka Springs Compliance Report

AR0021865

Month June

Year 2015

Type of Violation	Permit Limit	Permit Violation	Dates of Violation	Cause of Violation
7 DAY-AVG NH3	3.8	4.3	06/10/ 2015	High Rain Fall
7 DAY-AVG NH3	3.8	5.4	06/17/ 2015	High Rain Fall
MO-AVG NH3	2.5	4.0	06/2015	High Rain Fall

High water event, back in compliance rest of month.


I certify under penalty of law that I have personally examined the information submitted herein: and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. 18 U.S.C. 1001 and 33 U.S.C 1319 (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)

Signature of Cognizant or Ranking Official _____ Date _____

City of Eureka Springs
Department of Public Works
3174 East Van Buren
Eureka Springs, AR 72632-9498

PLACE STICKER AT TOP OF ENVELOPE TO THE RIGHT
OF THE RETURN ADDRESS, FOLD AT DOTTED LINE


CERTIFIED MAIL®



7014 1820 0001 5068 9488



1000



72118

U.S. POSTAGE
PAID
BERRYVILLE, AR
72616
JUL 25, 15
AMOUNT

\$4.65

R2304P119025-06

ADEQ Water Permits
5301 Northshore Drive
N. Little Rock, AR 72118-5317

