

City of Eureka Springs Compliance Report

AR0021865

Month May

Year 2013

Type of Violation	Permit Limit	Permit Violation	Dates of Violation	Cause of Violation
7 Day	3.8	6.6	05/15/2013	Pump Down
MO-Avg	2.5	2.6	05/2013	Pump Down

We have our motive pump back on line, as of 06/21/2013. The pump and an electric surge have proven to be a challenge in maintaining our process.

I certify under penalty of law that I have personally examined the information submitted herein: and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. 18 U.S.C. 1001 and 33 U.S.C 1319 (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)


Signature of Cognizant or Ranking Official



Date

06-24-13

City of Eureka Springs
Department of Public Works
3174 East Van Buren
Eureka Springs AR, 72632-9498



ADEQ- Water Permits
5301 Northshore Drive
North Little Rock, AR 72118-5317

