

# City of Eureka Springs Compliance Report

AR0021865

Month May

Year 2015

Type of Violation	Permit Limit	Permit Violation	Dates of Violation	Cause of Violation
7 DAY-AVG NH3	3.8	5.8	05/06/ 2015	High Rain Fall

High water event, back in compliance rest of month.

I certify under penalty of law that I have personally examined the information submitted herein: and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. 18 U.S.C. 1001 and 33 U.S.C 1319 (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)

Signature of Cognizant or Ranking Official



Date

6/24/15

City of Eureka Springs  
Department of Public Works  
3174 East Van Buren  
Eureka Springs, AR 72632-9498

POSTAGE ADDRESS FOLD AT DOTTED LINE  
**CERTIFIED MAIL®**



7014 1820 0001 5058 3762



1000



72118

U.S. POSTAGE  
PAID  
BERRYVILLE, AR  
72616  
JUN 27, 15  
AMOUNT

**\$4.65**

R2304P119025-06

ADEQ Water Permits  
5301 Northshore Drive  
N. Little Rock, AR 72118-5317

