


# City of Eureka Springs Compliance Report



AR0021865



Month May

Year 2016

Type of Violation	Permit Limit	Permit Violation	Dates of Violation	Cause of Violation
7 DAY-AVG PO4	1.0	1.2	05//2016	Increased Load

We were receiving more P in our influent than our plant's design. Have increased chemical flow and the first test run for June was back in line.

I certify under penalty of law that I have personally examined the information submitted herein: and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. 18 U.S.C. 1001 and 33 U.S.C 1319 (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)

Signature of Cognizant or Ranking Official

Date

06/25/16