

# City of Eureka Springs Compliance Report

AR0021865

Month September

Year 2015

Type of Violation	Permit Limit	Permit Violation	Dates of Violation	Cause of Violation
7 DAY-AVG NH3	3.8	6.5	09/02/2015	Equipment

This was the last sample above average due to the motive pump breakdown. We have achieved denitrification since our mixed liquor was reduced.

I certify under penalty of law that I have personally examined the information submitted herein: and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. 18 U.S.C. 1001 and 33 U.S.C 1319 (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)

Signature of Cognizant or Ranking Official



Date

10/22/15

City of Eureka Springs  
Department of Public Works  
3174 East Van Buren  
Eureka Springs, AR 72616-9201



1000

U.S. POSTAGE  
PAID  
EUREKA SPRINGS, AR  
72632  
OCT 26, 15  
AMOUNT  
**\$4.65**  
R2305E123300-02

**CERTIFIED MAIL®**



7015 0640 0004 2398 1323

ADEQ-Water Permits  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

