

City of Eureka Springs Compliance Report

AR0021865

Month April

Year 2014

Type of Violation	Permit Limit	Permit Violation	Dates of Violation	Cause of Violation
MO-AVG PO4	1.0	1.2	04/2014	alkalinity

Our influent BOD was lower than anticipated for this time of year. One sample was recorded at 89.0 mg/l. Increased chemical feed all samples below 1 mg/l since.

I certify under penalty of law that I have personally examined the information submitted herein: and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. 18 U.S.C. 1001 and 33 U.S.C 1319 (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)


Signature of Cognizant or Ranking Official  Date 05-23-2014

CERTIFIED MAIL™



7009 1410 0002 0698 5941

City of Eureka Springs
Department of Public Works
3174 E. Van Buren
Eureka Springs, AR 72632-9498



U.S. POSTAGE
PAID
EUREKA SPRINGS, AR
72632
MAY 27, 14
AMOUNT

\$7.19
00093837-02

1000

72118

ADEQ Water Permits
5301 Northshore Drive
N. Little Rock, AR 72118-5317

