

# City of Eureka Springs Compliance Report

AR0021865

Month July

Year 2012

Type of Violation	Permit Limit	Permit Violation	Dates of Violation	Cause of Violation
7 Day	2.0	PO4- 3.6-3.1	7-18 &7-25, 2012	Heat-Settings
MO-Avg	1.0	PO4- 2.9	07/2012	Heat-Settings
7 Day	3.8	NH3- 4.6	07-11,2012	Heat-Settings
MO-Avg-Loading	7.5	PO4-9.4	07/2012	Heat-Settings

With the heat, averaging over 30c in the basins and the addition of changing to timings to maximize our PO4 removal we lost part of our nutrient removal. I have hired Todd Beaver with MCE, who had made vast improvements at Decatur, with their SBRs. Todd had us stop the alum feed till we get our biology back in order. We are improving daily.

I certify under penalty of law that I have personally examined the information submitted herein: and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. 18 U.S.C. 1001 and 33 U.S.C 1319 (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)

Signature of Cognizant or Ranking Official



Date

08-23-2012

## Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: CITY OF JACKSONVILLE NPDES Permit No.: AC0021865 Monitoring Period (Month/Year): 07/2012

No Sanitary Sewer Overflows This Monitoring Period

Cause(s) of SSO		Summary Report Code Descriptions		
		SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evidence Adverse Health/ Environmental Impact		CR-Creek/Stream/River (specify)
E-Equipment Failure	G-Grease			
HC-Hydro Clean	LF-Line Failure	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch
R-Rainfall	RG-Roots / Grease			
RO-Roots	V-Vandalism	EFK-Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet
			HR-Hand Rodded	GR-Ground Surface
			EN-Referred to Engineering	PA-Paved Area
			PN-Public Notification	CB-Contained in Building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Discharge Location


[Signature]  
Signature of Cognizant or Ranking Official

08-23-2012  
Date

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

City of Eureka Springs  
Department of Public Works  
3174 East Van Buren  
Eureka Springs, AR 72632-9498


**CERTIFIED MAIL™**



7009 1410 0002 0698 5552



UNITED STATES  
POSTAL SERVICE



1000

72118

U.S. POSTAGE  
PAID  
BERRYVILLE, AR  
72616  
AUG 25, 12  
AMOUNT

**\$4.25**  
00086367-06

ADEQ  
Water-Permits  
5301 Northshore Drive  
N. Little Rock, AR 72118-5317