

Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: C174 of Augusta Storms NPDES Permit No.: AL0021865 Monitoring Period (Month/Year): 06/2012

No Sanitary Sewer Overflows This Monitoring Period

Cause(s) of SSO		Summary Report Code Descriptions		
		SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evidence Adverse Health/ Environmental Impact		CR-Creek/Stream/River (specify)
E-Equipment Failure	G-Grease			
HC-Hydro Clean	LF-Line Failure	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch
R-Rainfall	RG-Roots / Grease			
RO-Roots	V-Vandalism	EFK-Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet
			HR-Hand Rodded	GR-Ground Surface
			EN-Referred to Engineering	PA-Paved Area
			PN-Public Notification	CB-Contained in Building


Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Discharge Location

D Allen
Signature of Cognizant or Ranking Official

07-23-2012
Date

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

CITY OF EUREKA SPRINGS
PUBLIC WORKS
3174 E VAN BUREN
EUREKA SPRINGS, AL 32632



ADDP - WATER - PERMITS
5301 NORTH SAGE DRIVE
N. LITTLE ROCK, AL 32118-5317