

ADEQ

ARKANSAS
Department of Environmental Quality

June 25, 2013

Don O'Neal, General Manager
City of Wynne
121 East Merriman Avenue
Wynne, AR 72396

RE: NPDES Permit Number AR0021903, AFIN 19-00071
NPDES Permit Effluent Violations

Dear Mr. O'Neal,


A recent review of the above referenced permit has revealed the following permit effluent violations for the monitoring period ending April 2013:

DMR End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio
04/30/2013	001-A	Nitrogen, ammonia total (as N), MO AVG, mg/L	2.1	2.624	25%

As you know, Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit requires you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0823 or e-mail at suel@adeq.state.ar.us.

Sincerely,



Kevin Suel
Enforcement Analyst
Water Division, Enforcement Branch